



ECCENTRIC SECTION

NOTES:

1. TOP SLAB SHALL BE RATED FOR HS-20 LOADING.
2. APPLY NON-SHRINK GROUT TO INSIDE AND OUTSIDE OF ALL JOINTS, RINGS, RISERS AND FRAMES.
3. LADDER SHALL BE WELDED TO INSIDE OF MANHOLE. FIELD APPLY ASPHALT COATING TO WELDS.



**City of
Bellevue**

**STORM AND SURFACE
WATER UTILITY**

TITLE

TRAFFIC BEARING ACCESS FOR
CORRUGATED METAL MANHOLE

JANUARY 2011

NO SCALE

NO. **D-51**